

# Certificate of Compliance

**Certificate:** 1222928

**Master Contract:** 211306

**Project:** 2323598

**Date Issued:** December 24, 2010

**Issued to:** Rolec Gehäuse systemen GmbH  
Kreuzbreite 2  
D-31737 Rinteln  
GERMANY

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only*



*Ghislain Foulem*  
Issued by: G. Foulem

## PRODUCTS

CLASS -3211-11 – INDUSTRIAL CONTROL EQUIPMENT – Enclosures for Electrical Equipment

CLASS -3211-91 – INDUSTRIAL CONTROL EQUIPMENT – Enclosures for Electrical Equipment -Certified to US Standards

**Certificate:** 1222928

**Project:** 2323598



**Master Contract:** 211306

**Date Issued:** December 24, 2010

**Section A**

Die-cast aluminium enclosures for use with industrial control equipment, Enclosure Type 4, Series "aluNORM" , model designations AS, AD, AF, and AH; series "conFORM", model designations EK and EKF.

**Section B**

Plastic enclosures for use with industrial control equipment, Enclosure Type 4, Series "polyTOP", model designation PT, series "polyDOOR ", model designation PD.

**Notes**

1. These are metal enclosures intended for use with industrial control equipment where the acceptability of the combination has been determined by CSA International or another NRTL..
2. The Certification of this submittor's enclosures covers mechanical parts only (no electrical parts are involved).
3. The model designations may be followed by numeric suffices xyz. indicating the enclosure size
4. On manufacturers request also investigated to NEMA 250-2008, Enclosures for Electrical Equipment

**APPLICABLE REQUIREMENTS**

CSA C22.2 No. 94.1-07	Enclosures for Electrical Equipment – Non-environmental Considerations
CSA C22.2 No. 94.2-07	Enclosures for Electrical Equipment – Environmental Considerations
UL 50 - 12 <sup>th</sup> edition	Enclosures for Electrical Equipment – Non-environmental Considerations
UL 50E - 1 <sup>st</sup> edition	Enclosures for Electrical Equipment – Environmental Considerations

## *Supplement to Certificate of Compliance*

**Certificate:** 1222928

**Master Contract:** 211306

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
2323598	December 24, 2010	cCSAus - Update to report 1222928 to cover corrections and delete type numbers as per FIR request. CSA C22.2 No 94-1-07, 94-2-07; UL50 12th ed. UL 50E 1st ed.
1222928	October 30, 2001	Original Certification of Die-cast aluminum enclosures for use with industrial control equipment, Enclosure Type 4. Series "aluNORM", model designations AS, AD, AF, and AH; series "conFORM", model designations EK and EKF; Plastic enclosures for use with industrial control equipment, Enclosure Type 4, Series "polyTOP", model designation PT; series "polyTOP-Ex", model designation PT, series "polyDOOR", model designation PD.